


Since 1979

THE JOHN R. McADAMS COMPANY, INC.

MEMORANDUM

December 15, 2006

To: Melissa Socie
WD Partners

From: Brandon G. Plunkett, PE 

Re: **Home Depot at Myrtle Grove
Change Bulletin – 5S
Wilmington, North Carolina
HMD-06000**

C-2.0- Grading Plan

- Revised the pipe inverts connected CB14 and CB14A to accommodate the off-site 24" C905 Sewer Main conflict.

C-3.13 – Storm System and Utility Details

- Amend SD 4-01 Guidelines for Standard Hydrant. Modified per New Hanover County Fire Services to show standard threading on the 2 ½" Hose Nozzles versus the typical American Pipe Thread shown on original Wilmington detail.

Research Triangle Park, NC

Post Office Box 14005
Research Triangle Park,
North Carolina 27709
2905 Meridian Parkway
Durham, North Carolina 27713
800-733-5646
919-361-5000
919-361-2269 Fax

Charlotte, NC

5311 Seventy-Seven Center Drive,
Suite 66
Charlotte, North Carolina 28217
800-733-5646
704-527-0800
704-527-2003 Fax

www.johnrmcadams.com

Comprehensive Land Development Design Services

We help our clients succeed.